

SEA-BIRD ELECTRONICS, INC.

1808 136th Place N.E., Bellevue, Washington 98005 USA Telephone: (425) 643-9866 Telex: 292915 SBEI UR Fax: (425) 643-9954

email: seabird@seabird.com

SBE P/N 50110

DATE	REV	REVISION RECORD	AUTH	DR	CHK
9.27.04	В	Changed Hose Clamps	CB	KLP	

SBE 19 to Tritech Altimeter Mount Kit

Kit Contents

SBE P/N	Manufacturer P/N	Primary SBE Application	QTY
23696	SBE 19 Cage Tritech Mnt Blk	Main sensor mount block	1
30190	Bolt, 1/4-20 x 2-1/2 HEX SS	Secures mount block to cage	1
30216	Nut, ¹ / ₄ -20 nylon stop	Secures mount block to cage	1
30253	Washer, 1/4 fender, SS, 1"OD	Provides support for Bolt and nut	2
30409	Teflon Tape	Insulates Hose clamp against other materials	1
31334	Hose Clamp, AWAB 316 SS, #40	Secures Tritech to mount block	1
67019	SBE 19 Tritech Altimeter Mount Kit	Assembly drawing for Altimeter mount kit	1

Procedure for Kit Assembly

- 1. Block (23696) slides onto cage bottom bar as shown.
- 2. Secure block to age with bolt (30190) and washer (30253) and nut (30216).
- 3. Hose clamp should be supplied with tape installed.
 - a. To install tape, line up tape with underside of hose clamp at clamp end.
 - b. Run tape along inside of hose clamp, and smooth it down until no air bubbles exist between them.
 - c. With a razor, cut tape off along the sides of the hose clamp.
- 4. Mount altimeter to block as shown, and tighten hose clamp until snug.

Parent Part Number: 50110 SBE Drawings:

> 67019 SBE19 to Tritech Altimeter Mount Kit Assembly

Sea-Bird Electronics Procedure

PROCEDURE NUMBER: 67019

TITLE: SBE 19 to Tritech Altimeter Kit

REVISION: B

EFFECTIVE DATE: 9/27/2004

CHECKED BY: KLP PAGE 1 of 1

